



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03831784

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 08/28/2023

Inspection Time: 9:45 AM

Inspection Type: Electric Service Equipment

Inspection Code: 23

Meter Release:

Provider: CORE

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

1. Ped risers to extend 18" below grade 2. Ped terminations incomplete 3. Identify feeder neutral at all terminations per 200.6

Note-UFER in garage left of sub panels