



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-09982
Inspection Number: 03833176

Building Inspection Report

Permit Information

Job Address: 2247 MILLCREEK PL HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 09/01/2023
Inspection Time: 9:45 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Jon Dickey
Charge Reinspection Fee: No

Comments

Missing one bird stop flashing at upper front gable area to the left of where upper ladder was set