



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-09448
Inspection Number: 03837323

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 1497 FLINTWOOD RD FRANKTOWN
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 09/19/2023
Inspection Time: 12:58 PM
Inspection Type: Rough Plumbing
Inspection Code: 28
Outcome: Disapproved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No

Comments

1. S trap at new shower location 2. Foam all penetrations