



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-13580

Inspection Number: 03837393

## Building Inspection Report

### Permit Information

**Job Address:** 14684 CHICAGO ST PARKER  
**Job Type:** Roofing  
**Description:** Composition - Primary Residence

### Inspection Details

**Inspection Date:** 09/20/2023  
**Inspection Time:** 8:32 AM  
**Inspection Type:** Roofing  
**Inspection Code:** 34  
**Outcome:** Disapproved  
**Inspected By:** Greg Glenn  
**Charge Reinspection Fee:** No

### Comments

Bird stops at upper south elevation east and west ends have large gaps/ holes. Please seal, or cut metal tight to prevent moisture/ animal/ insect infiltration. Leave no gaps or holes. Please seal gaps/ holes at bird stop upper east elevation north end.