



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03837496

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 09/19/2023
Inspection Time: 8:40 AM
Inspection Type: Construction Meter
Inspection Code: 10
Meter Release: Yes
Provider: CORE
Outcome: Approved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No