



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-06405
Inspection Number: 02608836

Building Inspection Report

Code Reviewed Under: 1997 UBC

Permit Information

Job Address: 5378 COUNTRY CLUB DR LARKSPUR
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 01/30/2006
Inspection Time: 12:00 AM
Inspection Type: Construction Meter
Inspection Code: 10
Meter Release: Yes
Provider: IREA
Outcome: Approved
Inspected By: Troy Meissner
Charge Reinspection Fee: No