



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-02225

Inspection Number: 03847200

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 6754 LIONSHEAD PKWY LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 10/23/2023

Inspection Time: 11:42 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Henry VanSchaack

Charge Reinspection Fee: No

Comments

1) washer recep requires afci protection per 406.4(D) and 210.12

2) island and kitchen countertop receps require afci protection in addition to GFCI protection per 210.12

3) kitchen lights require afci protection per 210.12