



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-09448
Inspection Number: 03847830

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 1497 FLINTWOOD RD FRANKTOWN
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 10/24/2023
Inspection Time: 10:02 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

1. Smoke alarms required to be placed minimum of 36" horizontally from bathroom doors that contain tub/shower-R314
2. Exhaust fans require NM connectors at cable entry