



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-05762
Inspection Number: 02612658

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 9175 RED POPPY CT PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 02/16/2006
Inspection Time: 8:09 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Cancelled
Inspected By: John Mulligan
Charge Reinspection Fee: No