

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 23-09448 Inspection Number: 03849243

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 1497 FLINTWOOD RD FRANKTOWN Job Type: Building Description: RS - Residential Scope of Work: Alteration

Inspection Details

Inspection Date: 10/30/2023 Inspection Time: 11:52 AM Inspection Type: Final Electric Inspection Code: 42 Outcome: Disapproved Inspected By: Thomas Buzo Charge Reinspection Fee: No

Comments

Not ready. Courtesy walk only.

This permit is under new 2023NEC requirements. See 210.8 for GFCI protection requirements of Appliances and receptacles.

Areas that have been remodel - TR receptacles are required.
Spark rings req at kitchen back splash or install boxes flush to finish materials.
Receptacles under sink req GFCI and AFCI Protection.
Protect DW cord where it passes through cabinet.
Install Faceplate throughout project for scope of work.
Breaker lock req for hardwire appliances. 422
GFCI protection req for 120V -240V receptacles and Appliances as req per 210.8
AFCI protection req for all new and modified circuits. 210.12
Install Smoke and CO Detectors as req per 314&315 IRC