



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 23-16516

Inspection Number: 03849373

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

Job Address: 10557 JAGUAR DR LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

### Inspection Details

Inspection Date: 10/31/2023

Inspection Time: 10:51 AM

Inspection Type: Rough Electric

Inspection Code: 22

Outcome: Approved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

### Comments

AFCI altered/modified circuits

1 additional recep and smoke det added, CF relocated