



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-16516

Inspection Number: 03849375

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10557 JAGUAR DR LITTLETON

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 10/31/2023

Inspection Time: 12:52 PM

Inspection Type: Rough Frame

Inspection Code: 29

Outcome: Approved

Inspected By: Dusty Welz

Charge Reinspection Fee: No

Comments

1. Fire stop required for wire penetration into attic space. Please fire foam, email picture and then proceed to drywall.

2. Transfer air needed by final inspection.