



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 05-05762  
Inspection Number: 02613162

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 9175 RED POPPY CT PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 02/17/2006  
**Inspection Time:** 8:29 AM  
**Inspection Type:** Rough Electric  
**Inspection Code:** 22  
**Outcome:** Cancelled  
**Inspected By:** Rich Edgett  
**Charge Reinspection Fee:** No