



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087  
Inspection Number: 03850978

## Building Inspection Report

Code Reviewed Under: 2018 IRC

### Permit Information

**Job Address:** 5720 DISTANT VIEW PL PARKER  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 11/06/2023  
**Inspection Time:** 12:58 PM  
**Inspection Type:** Exterior Wall Sheathing  
**Inspection Code:** 104  
**Outcome:** Disapproved  
**Inspected By:** Fredrick Mooney  
**Charge Reinspection Fee:** No

### Comments

No plans