



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-11317

Inspection Number: 03853375

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: RS - Custom

Scope of Work: New

Inspection Details

Inspection Date: 11/15/2023

Inspection Time: 10:51 AM

Inspection Type: Final Plumbing

Inspection Code: 40

Outcome: Approved

Inspected By: Rick Chadwick

Charge Reinspection Fee: No

Comments

See Final Building