



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-15841
Inspection Number: 03856787

Building Inspection Report

Permit Information

Job Address: 9676 CHERRYVALE DR HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 11/29/2023
Inspection Time: 10:53 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Jon Dickey
Charge Reinspection Fee: No

Comments

Bird stop flashings and fascia flashing need to be tightly fitted where there is no big gaps at 2 spots above garage