



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-05762
Inspection Number: 02616810

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 9175 RED POPPY CT PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 03/07/2006
Inspection Time: 12:00 AM
Inspection Type: Driveway Form
Inspection Code: 20
Outcome: Disapproved
Inspected By: Jill Welle
Charge Reinspection Fee: No

Comments

res