

Douglas County Building Division 100 Third Street STE #20 Castle Rock, CO 80104 Phone: 303.660.7497 Email: dcbuilding@douglas.co.us

> Permit Number: 23-09448 Inspection Number: 03861751

## **Building Inspection Report**

Code Reviewed Under: 2021 IRC

## **Permit Information**

Job Address: 1497 FLINTWOOD RD FRANKTOWN Job Type: Building Description: RS - Residential Scope of Work: Alteration

## **Inspection Details**

Inspection Date: 12/18/2023 Inspection Time: 11:54 AM Inspection Type: Final Electric Inspection Code: 42 Outcome: Disapproved Inspected By: Justin Lett Charge Reinspection Fee: No

## **Comments**

1. DW cord requires bushing 2. Both receps above micro require GFCI/AFCI protection 3. AFCI protection for disposal and device required to be TR type 4. Lower dryer requires GFCI protection 5. Plates missing lower laundry 6. Complete smokes/COs lower level-all must interconnect throughout house and will test at next inspection 7. Upper coffee bar AFCI protection required at breaker-new circuit 8. AFCI protection required craft room lights/receps, kitchen counter right of sink, kitchen lighting