



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03862981

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 12/20/2023
Inspection Time: 10:33 AM
Inspection Type: Electric Trench
Inspection Code: 16
Outcome: Approved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

Trench from pedestal to house.

(2) 2-4/0AI 1-2/0AL and #2AL EGC

Note: keep ends of trench open at house to verify conduit and bell end fitting.