



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-03374

Inspection Number: 03864361

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 400 N RUSSELLVILLE RD FRANKTOWN

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 12/29/2023

Inspection Time: 12:51 PM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Disapproved

Inspected By: Justin Lett

Charge Reinspection Fee: No

Comments

1. Dryer requires GFCI protection-210.8 2. Receptacle in lower m bedroom behind door requires TR type-406.12