



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12388
Inspection Number: 03864691

Building Inspection Report

Permit Information

Job Address: 10268 CELESTINE PL PARKER
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 01/03/2024
Inspection Time: 11:21 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Mike White
Charge Reinspection Fee: No

Comments

Bird stop flashing required above the entryway. Approximately 2 1/2 feet on the left side, and about 6 feet of area at the back where shingle roof meets "soffit". Please call me at 703-317-7788 if you have any questions.