Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04087
Inspection Number: 03864841

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 01/03/2024
Inspection Time: 12:17 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: CORE
Outcome: Disapproved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

1)feeders not terminated at pedestal.
2)identify grounded conductors at main disconnects.
3)Remove green bonding screws at house disconnects. 250.24 (float neutrals and grounds)
4)Emergency service disconnect labels missing at disconnects
5)remove paint where ground lugs sit in disconnect enclosures.
6)#6 CU Conductor missing for IBT.