



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03864841

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 01/03/2024
Inspection Time: 12:17 PM
Inspection Type: Electric Service Equipment
Inspection Code: 23
Meter Release:
Provider: CORE
Outcome: Disapproved
Inspected By: Thomas Buzo
Charge Reinspection Fee: No

Comments

- 1)feeders not terminated at pedestal.
- 2)identify grounded conductors at main disconnects.
- 3)Remove green bonding screws at house disconnects. 250.24 (float neutrals and grounds)
- 4)Emergency service disconnect labels missing at disconnects
- 5)remove paint where ground lugs sit in disconnect enclosures.
- 6)#6 CU Conductor missing for IBT.