



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03864842

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 01/03/2024
Inspection Time: 10:35 AM
Inspection Type: Insulation Thermal
Inspection Code: 36
Outcome: Disapproved
Inspected By: Dusty Welz
Charge Reinspection Fee: No

Comments

1. Gasket all top plates communicating with attic space.
2. Foam all electrical bone in ceiling communicating with attic.
3. Okay to hang drywall in basement and exterior walls that are already gasketed.