



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 23-20922

Inspection Number: 03870170

Building Inspection Report

Permit Information

Job Address: 3850 MALLARD ST HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 01/29/2024
Inspection Time: 11:45 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Jon Dickey
Charge Reinspection Fee: No

Comments

Felt or ice and water needs to be on top of drip metal at gutter line at lower section