



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 05-07373  
Inspection Number: 02624131

## Building Inspection Report

Code Reviewed Under:

### Permit Information

Job Address: 5831 RAIN DANCE TRL LITTLETON  
Job Type: Building  
Description: RS - Custom  
Scope of Work: New

### Inspection Details

Inspection Date: 04/07/2006  
Inspection Time: 12:00 AM  
Inspection Type: Rough Frame  
Inspection Code: 29  
Outcome: Disapproved  
Inspected By: Brian Brown  
Charge Reinspection Fee: No

### Comments

res1