



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-16783
Inspection Number: 03875303

Building Inspection Report

Permit Information

Job Address: 10442 LONGLEAF DR PARKER
Job Type: Roofing
Description: Wood/Masonite Product - Primary Residence

Inspection Details

Inspection Date: 02/21/2024
Inspection Time: 2:23 PM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Greg Glenn
Charge Reinspection Fee: No

Comments

Bird stop and fascia flashing missing above and to the right of entry. Please seal or cut metal to fit and se use leaving no holes or gaps.

There is a shiner in the hip/ ridge cap at this location. Please seal.