



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711
Inspection Number: 03893682

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4848 RAINTREE CIR PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 05/08/2024
Inspection Time: 11:55 AM
Inspection Type: Rough Electric
Inspection Code: 22
Outcome: Approved
Inspected By: Curt Elliott
Charge Reinspection Fee: No

Comments

AL feeder to pool equipment panel to be pulled back into attic. Will change to CU in j-box with surface raceway to panel in equipment room.