



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 05-07373  
Inspection Number: 02633680

## Building Inspection Report

Code Reviewed Under:

### Permit Information

**Job Address:** 5831 RAIN DANCE TRL LITTLETON  
**Job Type:** Building  
**Description:** RS - Custom  
**Scope of Work:** New

### Inspection Details

**Inspection Date:** 05/17/2006  
**Inspection Time:** 12:00 AM  
**Inspection Type:** Electric Trench  
**Inspection Code:** 16  
**Outcome:** Disapproved  
**Inspected By:** Dave Ransom  
**Charge Reinspection Fee:** No

### Comments

res