



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 22-04087
Inspection Number: 03895879

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 05/17/2024
Inspection Time: 12:28 PM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Curt Elliott
Charge Reinspection Fee: No

Comments

Bedroom 5 closet light may not be over shelf