



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711
Inspection Number: 03897618

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4848 RAINTREE CIR PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 05/24/2024
Inspection Time: 9:46 AM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Disapproved
Inspected By: Brian Schroder
Charge Reinspection Fee: No

Comments

All "wet areas" tile backer board require non-corrosive screws with 7" OC spacing. All other areas are OK to mud/tape.