Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 22-04087
Inspection Number: 03898577

Building Inspection Report

Code Reviewed Under: 2018 IRC

Permit Information

Job Address: 5720 DISTANT VIEW PL PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 05/30/2024
Inspection Time: 2:21 PM
Inspection Type: Final Building
Inspection Code: 108
Outcome: Approved
Inspected By: Rick Chadwick
Charge Reinspection Fee: No