



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 05-05288  
Inspection Number: 02635468

## Building Inspection Report

Code Reviewed Under:

### Permit Information

Job Address: 1064 COCHETOPA DR LARKSPUR  
Job Type: Building  
Description: RS - Stock  
Scope of Work: New

### Inspection Details

Inspection Date: 05/24/2006  
Inspection Time: 2:42 PM  
Inspection Type: Exterior Lath  
Inspection Code: 33  
Outcome: Cancelled  
Inspected By: Kerry Keller  
Charge Reinspection Fee: No