



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-04197

Inspection Number: 03901090

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 3042 WYECLIFF WAY HIGHLANDS RANCH

Job Type: Building

Description: RS - Residential

Scope of Work: Alteration

Inspection Details

Inspection Date: 06/10/2024

Inspection Time: 11:21 AM

Inspection Type: Final Electric

Inspection Code: 42

Outcome: Approved

Inspected By: Matt Mazzara

Charge Reinspection Fee: No

Comments

1)group circuits conductors in new sub 200.4(B)

Correct and proceed