



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909
Inspection Number: 03904564

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 9900 SARA GULCH CIR PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/25/2024
Inspection Time: 10:19 AM
Inspection Type: Caisson Deck/Pole Barn
Inspection Code: 97
Outcome: Disapproved
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No

Comments

1. Unable to verify cage for piers. Form pour complete. Supply engineer letter for 2 piers.
2. North side of property appears to have a retaining wall. Supply engineering for retaining wall and revise plans to show location etc.