



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: [dcbuilding@douglasco.gov](mailto:dcbuilding@douglasco.gov)

Permit Number: 24-09597  
Inspection Number: 03904577

## Building Inspection Report

### Permit Information

**Job Address:** 9874 SILVER MAPLE RD HIGHLANDS RANCH  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 06/25/2024  
**Inspection Time:** 10:09 AM  
**Inspection Type:** Final HVAC  
**Inspection Code:** 39  
**Outcome:** Disapproved  
**Inspected By:** Richard Perrone  
**Charge Reinspection Fee:** No

### Comments

1. Missing tamper resistant/locking caps on refrigerant lines at condenser - M1411.9