



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglasco.gov

Permit Number: 24-09597  
Inspection Number: 03904971

## Building Inspection Report

### Permit Information

**Job Address:** 9874 SILVER MAPLE RD HIGHLANDS RANCH  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 06/25/2024  
**Inspection Time:** 10:11 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Richard Perrone  
**Charge Reinspection Fee:** No

### Comments

1. Neutrals and grounds shall not be bonded together in A/C disconnect - 250.24(A)(5).
2. Provide listing/documentation for Thomas and Betts classified breaker for use in Siemens/ITE panelboard - 110.3(B).
3. CO detectors required outside of all bedrooms and within 15' of door - IRC R315.