



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-09597
Inspection Number: 03904971

Building Inspection Report

Permit Information

Job Address: 9874 SILVER MAPLE RD HIGHLANDS RANCH
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 06/25/2024
Inspection Time: 10:11 AM
Inspection Type: Final Electric
Inspection Code: 42
Outcome: Disapproved
Inspected By: Richard Perrone
Charge Reinspection Fee: No

Comments

1. Neutrals and grounds shall not be bonded together in A/C disconnect - 250.24(A)(5).
2. Provide listing/documentation for Thomas and Betts classified breaker for use in Siemens/ITE panelboard - 110.3(B).
3. CO detectors required outside of all bedrooms and within 15' of door - IRC R315.