



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-09838
Inspection Number: 03905030

Building Inspection Report

Permit Information

Job Address: 8976 EDGEWOOD LN HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 06/28/2024
Inspection Time: 4:00 PM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Disapproved
Inspected By: Greg Glenn
Charge Reinspection Fee: No

Comments

Please seal nails in upper back bird stop and secure or seal stop to soffit.