



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 23-12711
Inspection Number: 03906849

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 4848 RAINTREE CIR PARKER
Job Type: Building
Description: RS - Residential
Scope of Work: New

Inspection Details

Inspection Date: 07/03/2024
Inspection Time: 10:52 AM
Inspection Type: Shower Pan
Inspection Code: 65
Outcome: Approved
Inspected By: Robert Stratton
Charge Reinspection Fee: No

Comments

Homeowners son granted me access to the pool house, shower pan is approved