



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-10522  
Inspection Number: 03907144

## Building Inspection Report

### Permit Information

**Job Address:** 7601 PRESERVATION TRL PARKER  
**Job Type:** Electrical  
**Description:** Other - ELECTRIC FOR WATER FEATURES

### Inspection Details

**Inspection Date:** 07/05/2024  
**Inspection Time:** 11:50 AM  
**Inspection Type:** Final Electric  
**Inspection Code:** 42  
**Outcome:** Disapproved  
**Inspected By:** Justin Lett  
**Charge Reinspection Fee:** No

### Comments

1. NM not permitted in exterior raceway 2. Connector required at NM entry into non metallic jbox 3. Sheathing required into jbox 1/4" minimum