



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-09838
Inspection Number: 03907491

Building Inspection Report

Permit Information

Job Address: 8976 EDGEWOOD LN HIGHLANDS RANCH
Job Type: Roofing
Description: Composition - Primary Residence

Inspection Details

Inspection Date: 07/09/2024
Inspection Time: 9:36 AM
Inspection Type: Roofing
Inspection Code: 34
Outcome: Approved
Inspected By: Jon Dickey
Charge Reinspection Fee: No