



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-10666
Inspection Number: 03907783

Building Inspection Report

Permit Information

Job Address: 9351 SUMMIT RD PARKER
Job Type: Mechanical
Description: Furnace/AC Combo (Primary Residence)

Inspection Details

Inspection Date: 07/09/2024
Inspection Time: 3:02 PM
Inspection Type: Air Conditioner
Inspection Code: 55
Outcome: Disapproved
Inspected By: Justin Lett
Charge Reinspection Fee: No

Comments

Locking caps required at refrigerant ports