



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909
Inspection Number: 03909085

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 9900 SARA GULCH CIR PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 07/16/2024
Inspection Time: 3:04 PM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Disapproved
Inspected By: Fredrick Mooney
Charge Reinspection Fee: No

Comments

Need 5 psi test. Pipe not supported at 45 degrees offset at exterior wall/corner.