



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 05-07373
Inspection Number: 02640354

Building Inspection Report

Code Reviewed Under:

Permit Information

Job Address: 5831 RAIN DANCE TRL LITTLETON
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 06/13/2006
Inspection Time: 12:00 AM
Inspection Type: Exterior Lath
Inspection Code: 33
Outcome: Approved
Inspected By: Brian Brown
Charge Reinspection Fee: No