



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglas.co.us

Permit Number: 24-01909
Inspection Number: 03909858

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 9900 SARA GULCH CIR PARKER
Job Type: Building
Description: RS - Custom
Scope of Work: New

Inspection Details

Inspection Date: 07/18/2024
Inspection Time: 12:06 PM
Inspection Type: Underground Plumbing
Inspection Code: 12
Outcome: Approved
Inspected By: Brian Schroder
Charge Reinspection Fee: No

Comments

Adjust kitchen sink drain to achieve 1/8" minimum slope. Correct as required.