



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-10372
Inspection Number: 03910880

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10245 BANE BERRY PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 07/23/2024
Inspection Time: 11:31 AM
Inspection Type: Rough Frame
Inspection Code: 29
Outcome: Approved
Inspected By: Anthony Frank
Charge Reinspection Fee: No

Comments

Windows have not been replaced at this point, I walked with the builder in reference to tempered glass windows to be addressed.