



Douglas County Building Division
100 Third Street STE #20
Castle Rock, CO 80104
Phone: 303.660.7497
Email: dcbuilding@douglasco.gov

Permit Number: 24-10372
Inspection Number: 03913396

Building Inspection Report

Code Reviewed Under: 2021 IRC

Permit Information

Job Address: 10245 BANE BERRY PL HIGHLANDS RANCH
Job Type: Building
Description: RS - Residential
Scope of Work: Alteration

Inspection Details

Inspection Date: 08/01/2024
Inspection Time: 12:31 PM
Inspection Type: Drywall
Inspection Code: 38
Outcome: Approved
Inspected By: Robert Stratton
Charge Reinspection Fee: No