



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-05113

Inspection Number: 03915781

## Building Inspection Report

Code Reviewed Under: 2021 IRC

### Permit Information

Job Address: 2852 MYSTIC DOE CT FRANKTOWN

Job Type: Building

Description: AU - Garage

Scope of Work: New

### Inspection Details

Inspection Date: 08/13/2024

Inspection Time: 10:46 AM

Inspection Type: Electric Trench

Inspection Code: 16

Outcome: Approved

Inspected By: Curt Elliott

Charge Reinspection Fee: No

### Comments

125' trench from house to garage. 4/0-4/0-2/0-4 installed in trench.