



Douglas County Building Division  
100 Third Street STE #20  
Castle Rock, CO 80104  
Phone: 303.660.7497  
Email: dcbuilding@douglas.co.us

Permit Number: 24-09597  
Inspection Number: 03917199

## Building Inspection Report

### Permit Information

**Job Address:** 9874 SILVER MAPLE RD HIGHLANDS RANCH  
**Job Type:** Mechanical  
**Description:** Furnace/AC Combo (Primary Residence)

### Inspection Details

**Inspection Date:** 08/20/2024  
**Inspection Time:** 12:22 PM  
**Inspection Type:** Final HVAC  
**Inspection Code:** 39  
**Outcome:** Approved  
**Inspected By:** Richard Perrone  
**Charge Reinspection Fee:** No